

MALONE CAMPBELL ROAD FACILITY, TEXAS CITY, GALVESTON COUNTY, TEXAS

Week ending 09/10/2015

On July 6, 2015 FOSC Zehner initiated an emergency pump down of contaminated storm at the facility which was authorized by the R6 Superfund Division Director. The initiation of emergency actions were necessary to abate the imminent and substantial threat of discharge of several hundred thousand gallons of contaminated storm water located on the Site from several multi-inch rainfalls associated with Tropical Storm Bill and other sub-tropical weather fronts that had impacted the Site during May and June of 2015. On-site disposal well WDW-138 began operations on 07/06/15. The FOSC also authorized the operation of the additional on-site injection well WDW-73. A "start-up" test was initiated on WDW-73 on July 14 to bring that well online. The WDW-73 falloff test was conducted from July 27 to July 31. WDW-73 encountered some minor mechanical difficulties from August 3 to 7 due to packing leak and coupler malfunction; the well is presently injecting stormwater. The MCP contractor has completed the Mechanical Integrity Test and Final Falloff Test Report for WDW-73 and has submitted it to EPA Superfund and UIC.

Warren Zehner 214-789-1584, David Abshire 214-665-7188